

LICENCE N° 12305

HOW TO READ THIS CERTIFICATION LICENCE?

As *end product references* (cfr. catalogues, website, packaging, ...) aren't identical to *certification references* (cfr. certification licences), you'll find below an explanatory table.

Niko declares that the *end product references* in the left column correspond with the *certification references* in the right column.

| End product reference | Certification reference |
|---|-------------------------|
| 100-26610, 122-26610, 197-26610, 198-26610, 199-26610 | -3.1+.2266 |

Sint-Niklaas, 06/12/2013



Rony Haentjens
Certification & Standardization Officer

LICENCE

No.:12305

(Replaces No. 11722)

Issued to:

Applicant:

Niko N.V.

**Industriepark-West 40
9100 SINT-NIKLAAS**

Licensee:

NIKO N.V.

**Industriepark-West 40
9100 SINT-NIKLAAS**

Product : **Two-pole socket-outlets for household and similar purposes**

Trade name(s) : **NIKO**

Type(s)/model(s) : **- 3.1+.2266**

The product and any acceptable variation thereto is specified in the Annex to this licence and the documents therein referred to.

CEBEC Registered Quality hereby declares that the above-mentioned product has been certified on the basis of :


- a type test according to the standard NBN C 61-112-1
- an inspection of the production location according to CCA Group Operational Document CIG 021
- a certification agreement with the number 14

CEBEC Registered Quality hereby grants the right to use the CEBEC certification mark



The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 28/08/2001


ir. R. Maquestiau,
Managing Director

© Only integral publication of this certificate, including the annex, is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

| | | |
|---|---|--|
| Product | : | Two-pole socket-outlets for household and similar purposes |
| Trade name | : | NIKO |
| Types | : | -3.1+.2266 |
| Rated current | : | 10/16A |
| Rated voltage | : | 250V~ |
| Degree of protection against harmful ingress of water | : | IP20 |
| Provision for earthing | : | with earthing pin |
| Method for connecting the cable | : | rewirable |
| Type of terminals | : | screw-type |
| Degree of protection against electric shock | : | increased protection |
| Existence of enclosures | : | enclosed |
| Existence of shutters | : | with shutters |
| Method of application/ mounting of the socket-outlet | : | floor recessed type |
| Method of installation | : | design A |
| Colours | : | Cream, Red, Orange, Green |

TESTS

Test requirements

NBN C 61-112-1

Test results

The test results are laid down in CEBEC Test File 574602/01.



Remarks

This certificate replaces the CEBEC licence No. 11722 and is based on STR/B07/2001 and TRF's SMT 01-004 & SMT 01-004a.

Checked by, project leader :

J.-P. BRECHT

i.o.  28/8/2001

Department Manager,
Product Certification :

 20.08.15

Certification Manager :


20.08.15

FACTORY-LOCATION(S)

Niko N.V.
Industriepark-West 40
9100 SINT-NIKLAAS