

# CERTIFICATE

Number: **2140888.04**

Issued to:

Applicant:

**Niko N.V.**

**Industriepark West 40**

**9100, Sint-Niklaas, Belgium**

Manufacturer/Licensee:

**Niko N.V.**

**Industriepark West 40**

**9100, Sint-Niklaas, Belgium**



Product(s) : combinations of rocker switches

Trade name(s) : NIKO

Type(s)/model(s) : 7\*\*-32605+-350

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA Quality hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60669-1:1999 + A1:2002 + A2:2008
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367

KEMA Quality hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 1 December 2010 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood  
Managing Director

H.L. Schendstok  
Certification Manager

ACCREDITED BY  
THE DUTCH COUNCIL  
FOR ACCREDITATION



© Integral publication of this certificate is allowed

## SPECIFICATION OF THE CERTIFIED PRODUCT

### Product data

product	:	combinations of rocker switches
trade name	:	NIKO
type	:	7**-32605+-350
pattern no.	:	6+6
method of mounting	:	surface type
cover	:	housing of thermoplastic material
terminals	:	screwless terminals
rated current	:	10 AX
rated voltage	:	250 V~
degree of protection	:	IP55, IK07
programm	:	HYDRO
markings	:	-tradename, series-indication and electrical ratings on the base -tradename and suffix for the housing on this part

### Additional information

The in this certificate mentioned type shall be used in combination with the housings as mentioned in the KEMA certificate 2140888.06.

## TESTS

### Test requirements

EN 60669-1:1999 + A1:2002 + A2:2008

### Test result

The test results are laid down in KEMA Quality test file 2140888.04.

### Remarks

This certificate is also based on the SGS CEBEC CB Test Certificate BE-2421.

### Conclusion

The examination proved that all test requirements were met.

Tested by : SGS CEBEC

Checked by : H.R.M. Barends

### Factory locations

Niko N.V.  
Industriepark West 40, 9100, Sint-Niklaas  
Belgium

LICENCE N° 2140888.04


## HOW TO READ THIS CERTIFICATION LICENCE?

As *end product references* (cfr. catalogues, website, packaging, ...) aren't identical to *certification references* (cfr. certification licences), you'll find below an explanatory table.

Niko declares that the *end product references* in the left column correspond with the *certification references* in the right column.

End product reference	Certification reference
700-32605	7**-32605+-350

Sint-Niklaas, 15/12/2014



Rony Haentjens  
Certification & Standardization Officer