

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Manufacturer/Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product(s) : socket-outlets (2-pole)
Trade name(s) : NIKO
Type(s)/model(s) : ***_67815, ***_67825, ***_67835, ***_67845

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1: 2006 + A2: 2013, NEN 1020:1987 + A2: 2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 9 January 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2174226.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.L. Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	socket-outlets (2-pole)
trade name	:	NIKO
types	:	***_67815, ***_67825, ***_67835, ***_67845
method of mounting	:	flush-type
cover	:	singular cover plate of thermoplastic material
terminals	:	screwless terminals
rated current	:	16 A
rated voltage	:	250 V~
earthing	:	with side earthing-contacts
design	:	two-fold
markings	:	-tradename, series-indication and electrical ratings on the socket-outlet

Product data - type *_67825**

design	:	safety socket-outlet
--------	---	----------------------

Product data - type *_67845**

design	:	safety socket-outlet
--------	---	----------------------

TESTS**Test requirements**

IEC 60884-1:2002 + A1:2006 + A2:2013
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in DEKRA test file 2174226.01.

Remarks

This certificate replaces our certificate 2003637.01 dated 2000-07-26.

Conclusion

The examination proved that all test requirements were met.

Tested by	:	T. Cai
Checked by	:	H.R.M. Barends

**Factory locations**

Niko N.V.
Industriepark West 40, 9100, Sint-Niklaas
Belgium